

## IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Our water system recently violated drinking water standards. Although this was not an emergency, as our customer, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

### Marshall County Rural Water District #2 Has Levels of Total Trihalomethanes (TTHMs) Above Drinking Water Standards

We routinely monitor for the presence of drinking water contaminants. Testing results we received for the indicated time period(s) show that our system exceeds the standard, or maximum contaminant level (MCL), for total trihalomethanes (TTHM). The standard MCL for TTHM is 0.080 mg/L. It is determined by averaging all the samples collected at each sampling location for the past 12 months. The level of total trihalomethanes averaged at our system's location was the following:

<u>Twelve-month time period</u>	<u>Locational Running Annual Average with Sample Location</u>
Third Quarter 2024	0.091 MG/L - LITTLE CITY WATER TOWER
Third Quarter 2024	0.084 MG/L - MAIN OFFICE OF WASHITA POINT RETREAT

What should I do? There is nothing you need to do unless you have a severely compromised immune system, have an infant or are elderly. These people may be at increased risk and should seek advice about drinking water from their health care providers.

What does this mean? This is not an emergency. If it had been, you would have been notified immediately.

*However, some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidney, or central nervous system, and may have an increased risk of getting cancer.*

CORRECTIVE ACTION: What happened? What is done? When will the violation be resolved?

Excessive rain fall - We have changed chemical to help improve TOC removal and change window to bring water into the plant at a different level - because of being a 4 quarter average it will in 2025.

For further information contact: Robert Moore @ 580-795-3368

*Please share this information with all other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and Businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.*

This Notice is being sent to you by Marshall County Rural Water District #2

PWS Number      OK1010848      Case Number:      CO 23-098      Date distributed: 11-22-24